

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1597:114 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: TEPG-US, 91 Technology Drive, Westminister, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 430660 and *T301-0241 Supervised IAM Monitor Module; 430664 and *T301-0242 IAM Relay Module; 430666 and *T301-0244 Class "A" ZAM Monitor Module; 430665 and *T301-0245 Class "B" ZAM Monitor Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: *24 VDC
*30 VDC: 430664, *T301-0242, *T301-0244

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

XLF: 7300-0026:223

*Rev. 11-19-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 19, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**